

ANNUAL WATER QUALITY REPORT

Reporting Year 2022

Presented By
City of Canfield



Your Water Quality Report

The City of Canfield has prepared the following report on the water quality from Mahoning Valley Sanitary District (MVSD) and is currently up to date for 2022 with its license to operate your drinking water system. This report is required by the Safe Drinking Water Act.

Community Participation

Public participation and comments regarding water are encouraged at regular city council meetings on the first and third Wednesday of every month or through the office of the city manager, who can be reached at (330) 533-1101.

Where Does My Water Come From?

MVSD uses surface water drawn from the Meander Creek Reservoir. A copy of the MVSD Consumer Confidence Report is included for reference.

How Long Can I Store Drinking Water?

The disinfectant in drinking water will eventually dissipate even in a closed container. If that container housed bacteria prior to filling up with the tap water the bacteria may continue to grow once the disinfectant has dissipated. Some experts believe that water could be stored up to six

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The



U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.

Water Conservation Tips

You can play a role in conserving water and saving yourself money in the process by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water. Here are a few tips:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

QUESTIONS?

For technical water quality information, contact MVSD at (330) 652-3614. For information regarding distribution, service, pressure, lead and copper sampling results, or discolored water, contact John Rapp or Anthony Snovak, Canfield Public Works Department, at (330) 533-1101. The City of Canfield is licensed to operate as a public water system (OH5000503).

Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.


For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Source Water Assessment

A Source Water Assessment Plan (SWAP) is now available at the MVSD office. This plan is an assessment of the delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area and a determination of the water supply's susceptibility to contamination by the identified potential sources.

For the purpose of source water assessments in Ohio, all surface waters are susceptible to contamination. By their nature, surface waters are readily accessible and can be contaminated by chemicals and pathogens, which may rapidly arrive at the public drinking water intake with little warning or time to prepare. MVSD's drinking water source protection area is susceptible to runoff from row crop agriculture and animal feedlot operations, oil and gas wells, failing home and commercial septic systems, road/rail crossings, and new housing and commercial development that could raise runoff from roads and parking lots. MVSD treats its supply to meet drinking water quality standards, but no single treatment technique can address all potential contaminants.

According to the SWAP, our water system had a susceptibility rating of moderate. The potential for water quality impacts can further be decreased by measures to protect Meander Creek Reservoir and its watershed. More detailed information is provided in the SWAP, which can be obtained by calling Jon Jamison at (330) 652-3614. To view the approved MVSD Meander Creek Reservoir Drinking Water Source Protection Plan, visit meanderwater.org, Administrative Public Records.



Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. A list of laboratories certified in the State of Ohio to test for lead may be found at <http://www.epa.ohio.gov/ddagw> or by calling (614) 644-2752. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791 or at www.epa.gov/safewater/lead.

Test Results

Our water is monitored for many different kinds of substances on a very strict sampling schedule, and the water we deliver must meet specific health standards. Here, we only show those substances that were detected in our water (a complete list of all our analytical results is available upon request). Remember that detecting a substance does not mean the water is unsafe to drink; our goal is to keep all detects below their respective maximum allowed levels. Note that we have a current, unconditioned license to operate our water system.

The state recommends monitoring for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Alachlor (ppb)	2022	2	0	<0.100	NA	No	Runoff from herbicide used on row crops
Antimony (ppb)	2022	6	6	<3.0	NA	No	Discharge from petroleum refineries; Fire retardants; Ceramics; Electronics; Solder
Arsenic (ppb)	2022	10	0	<3.0	NA	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Atrazine (ppb)	2022	3	3	<0.072	NA	No	Runoff from herbicide used on row crops
Barium (ppm)	2022	2	2	<10	0.01 -	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	2022	4	4	<0.5	NA	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	2022	5	5	<0.5	NA	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; Runoff from waste batteries and paints
Chlorine (ppm)	2022	[4]	[4]	1.80	0.98–2.5	No	Water additive used to control microbes
Chromium (ppb)	2022	100	100	<10.0	NA	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	2022	200	200	<0.005	NA	No	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	2022	4	4	1.02	0.86–1.24	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAAs]–Stage 1 (ppb)	2022	60	NA	28.88	23.7–36.3	No	By-product of drinking water disinfection
Mercury [inorganic] (ppb)	2022	2	2	<0.200	NA	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nickel (ppb)	2022	100	NA	<10.0	NA	No	Plumbing fixtures and fertilizers
Nitrate (ppm)	2022	10	10	0.24	<0.10–0.44	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	2022	50	50	<3.0	NA	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Simazine (ppb)	2022	4	4	<0.052	NA	No	Herbicide runoff
Thallium (ppb)	2022	2	0.5	<1.0	NA	No	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories
Total Organic Carbon [TOC] (removal ratio)	2022	TT ¹	NA	1.62	1.62–1.79	No	Naturally present in the environment
TTHMs [total trihalomethanes]–Stage 1 (ppb)	2022	80	NA	51.83	38.4–66.6	No	By-product of drinking water disinfection
Turbidity² (NTU)	2022	TT	NA	0.09	0.04–0.09	No	Soil runoff
Turbidity (lowest monthly percent of samples meeting limit)	2022	TT = 95% of samples meet the limit	NA	100	NA	No	Soil runoff

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH %ILE)	RANGE LOW-HIGH	SITES ABOVE AL/TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2022	1.3	1.3	0.0896	<0.01–0.726	0/80	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2022	15	0	ND	<5–200	2/80 ³	No	Lead service lines; Corrosion of household plumbing systems, including fittings and fixtures; Erosion of natural deposits

UNREGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Bromochloromethane (ppb)	2022	9.58	7.13–13.30	Individual chemical found in disinfection by-products
Chloroform (ppb)	2022	39.6	30.4–48.9	Individual chemical found in disinfection by-products

¹The value reported under Amount Detected for TOC is the lowest ratio of percentage of TOC actually removed to percentage of TOC required to be removed. A value of greater than 1 indicates that the water system is in compliance with TOC removal requirements. A value of less than 1 indicates a violation of the TOC removal requirements.

²Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.

³Two samples contained lead above the AL: Site 1 (200 ppb) Site 2 (32.1 ppb)

Definitions

90th %ile: The levels reported for lead and copper represent the 90th percentile of the total number of sites tested. The 90th percentile is equal to or greater than 90% of our lead and copper detections.

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

removal ratio: A ratio between the percentage of a substance actually removed to the percentage of the substance required to be removed.

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.